

DIVISION 2 – SITEWORK

Section Number	Title
02000	SITE WORK
02010	Subsurface Investigation
02012	Standard Penetration Tests
02016	Seismic Investigation
02050	Demolition
02080	Asbestos Removal
02100	SITE PREPARATION
02110	Site Clearing
02115	Selective Clearing
02140	Positive Drainage
02200	EARTHWORK
02210	Grading
	Grading and Retention
02220	Excavating, Backfilling & Compacting
02225	Rock Clause
02230	Base Course
	Granular Sub-base
	Granular Base
02270	Slope Protection and Erosion Control
02280	Soil Treatment
	Termite Control
02350	PILES AND CAISSONS
02360	Driven Piles
02380	Caissons
02500	PAVING AND SURFACING
02510	Asphaltic Concrete Paving
02515	Unit Pavers
	Brick Pavers
	Concrete Pavers
02525	Curbs
	Concrete Curbs
	Precast Concrete Curbs
02540	Synthetic Surfacing
02545	Surfacing
	Aggregate Surfacing-Chipseal
	Bituminous Surface Course
02575	Pavement Repair
02580	Pavement Marking
	Roadway and Parking Marking
02600	PIPED UTILITY MATERIALS
02605	Manholes and Cleanouts
02610	Pipes and Fittings
	Cast-Iron Pipe
	Ductile Iron Pipe
	Mineral Fiber Reinforced Cement Pipe
	Plastic Pipe
	Steel Pipe
	Vitrified Clay Pipe

DIVISION 2 – SITEWORK

Section Number	Title
02640	Valves and Cocks Valve Boxes
02660	Water Distribution
02665	Domestic Water Systems Fire Water Systems Heating Water Systems
02675	Disinfection of Water Distribution Systems
02680	FUEL DISTRIBUTION
02685	Gas Distribution System
02695	Steam Distribution System
02700	SEWERAGE AND DRAINAGE
02720	Storm Sewage Systems
02730	Sanitary Sewage Systems
02760	Restoration of Underground Pipelines
02762	Inspection of Pipelines
02764	Sealing Existing Pipelines
02780	Power and Communications
02785	Electrical Power Transmission
02790	Communication Transmission
02800	SITE IMPROVEMENTS
02810	Irrigation Systems Trenching Pipe and Fittings Control Wires Valves Clocks Heads Backflow Prevention
02830	Fences and Gates Chain Link Fences and Gates Ornamental Metal Fences and Gates Wood Fences and Gates
02840	Walk, Road and Parking Appurtenances Bicycle Racks Guardrails Parking Barriers Parking Bumpers Signage
02860	Playfields and Equipment Recreational Facilities
02870	Site and Street Furnishings Trash and Litter Receptors Tree Grates
02900	LANDSCAPING

DIVISION 2 – SITEWORK

Section Number	Title
	Planting List
	Focus Plants
	Trees
	Shrubs
	Groundcover
	Flowers
02910	Shrub and Tree Transplanting
02920	Soil Preparation (Top soil)
02930	Lawns, Grasses, Wildflowers Hydroseeding Sodding
02950	Trees, Plants and Ground Covers Temporary Protection Repair and Replacement of Trees, Shrubs and Lawn Trees and Shrubs
02970	Landscape Maintenance

DIVISION 2 – SITEWORK

Section Number	Title
02000	SITE PREPARATION

General

This section applies to all new buildings, building expansions, utility expansions, parking structures, surface parking lots, campus mall amenities, or any other design/construction activity that materially changes or affects the current features found on campus. Areas incorporated in this section are civil surveys, archaeological studies and utility mapping.

Design Standard

All existing built site features shall be noted as to their disposition during and after construction, i.e., removed, relocated, demolished, stored, etc. Contractor is to provide record photographs, prior to the start of construction, documenting the condition of site features to remain.

All landscape material (trees, shrubs, etc.) and irrigation supply devices shall be noted as to remain, stored, relocated or demolished. If existing plant material is to remain or be stored for future project use, it shall be noted as the GC's responsibility to maintain such plant material for the duration of construction. Unless noted otherwise all existing landscaping shall be returned to original or better condition.

Any existing site feature (built or plant material) shall clearly be identified as to whom will remove, relocate, demolish or store it (the GC or NAU).

02010	Subsurface Investigation
-------	--------------------------

Any project requiring subsurface investigation work shall be coordinated through the Facilities Development office. Such work shall be preformed by an independent testing agency. A/e to provide list of testing required. Identify the type of test, # of tests, frequency of tests, requirements of tests, etc.

02012	Standard Penetration Tests
-------	----------------------------

02016	Seismic Investigation
-------	-----------------------

02050	Demolition
--------------	-------------------

The Contractor shall ensure that all applicable notifications are completed and submitted to the Arizona Department of Environmental Quality (ADEQ) as outlined in 40 CFR 61.145(b), EPA's asbestos National Emission Standard for Hazardous Air Pollutants (NESHAP) regulation. Notification(s) must be completed prior to all demolition or renovation work as a result of construction activities that impact asbestos-containing materials (ACM).

All demolition and renovation construction activities involving ACM must be in compliance with all applicable NESHAP regulations. The current State of Arizona NESHAP coordinator located at ADEQ is Jon Marting and can be reached at (602) 207-2333.

Construction Site Stormwater Runoff Control

The Contractor shall apply to the Arizona Department of Environmental Quality (ADEQ) for a construction general permit prior to site work. Upon issuance and approval of the general permit from ADEQ, the Contractor shall submit a copy to the NAU Project Manager for review and recordkeeping purposes.

DIVISION 2 – SITEWORK

Section Number	Title
----------------	-------

	<p>The Contractor shall develop, implement, and enforce a site-specific Storm Water Pollution Prevention Plan (SWPPP) to reduce pollutants in any stormwater runoff to the Municipal Separate Storm Sewer System (MS4) from construction activities that result in a land disturbance of greater than or equal to one acre. Reduction of stormwater discharges from construction activity disturbing less than one acre must be included in the program if that construction activity is part of a larger common plan of development or sale that would disturb one acre or more.</p>
--	---

	<p>The Contractor shall incorporate erosion and sediment control in the site-specific SWPPP. In addition, describe the procedure to control and properly dispose of wastes, such as discarded building materials, concrete truck washout, chemicals, litter, and sanitary waste at the construction site that may cause adverse impacts to water quality.</p>
--	---

	<p>Work may not commence until all site plans or SWPPPs have been reviewed for potential water quality impacts, including erosion and sediment control, control of wastes and their accumulation, and any other potential adverse stormwater impacts that must be examined according to the requirements of the Stormwater Management Plan. Before ground is broken at the construction site, NAU Project Management staff and/or Environmental Health & Safety (EHS) shall review the site plans or SWPPP and verify (in written communication with the construction site operator) that the BMPs for the site are appropriate.</p>
--	--

	<p>After work has commenced, the Contractor shall implement procedures for regular site inspections and enforcement of stormwater runoff control measures; these may be incorporated into the SWPPP or may be a separate procedure outlined by the Contractor. The Contractor shall implement ongoing inspections and recordkeeping until project completion. If the Contractor, NAU Project Manager, or NAU EHS discover a compromise to stormwater runoff controls or a non-compliant condition arises in reference to the site-specific SWPPP, the Contractor shall immediately implement corrective action. Insufficient corrective action may result in a temporary “cease work” project condition.</p>
--	--

Post-Construction Stormwater Management in New Development and Redevelopment

	<p>The Contractor shall develop, implement, and enforce the installation of structural or non-structural stormwater controls to address post-construction stormwater runoff from new development and redevelopment projects that disturb greater than or equal to one acre, including projects less than one acre that are part of a larger common plan of development or sale, and discharge into the small MS4. The Contractor shall develop and implement strategies that include a combination of structural and/or non-structural controls appropriate for the community and ensure that the controls are in place and would prevent or minimize water quality impacts from post-construction stormwater runoff.</p>
--	---

	<p>The Contractor shall incorporate the post-construction controls in a site-specific SWPPP or in the blueprint plans. Work may not commence until post-construction control measures have been reviewed for potential future water quality impacts to the community. Before ground is broken at the construction site, NAU Project Management staff and/or Environmental Health & Safety (EHS) shall review the blueprints or SWPPP and verify (in written communication with the construction site operator) that the control measure(s) for the site are appropriate and will not adversely affect the community.</p>
--	--

	<p>After work has commenced, the Contractor shall be responsible for the proper installation of post-construction stormwater management controls at the site. If the Contractor, NAU Project Manager, or NAU EHS discover a compromise to stormwater runoff control installation, the Contractor shall immediately implement corrective action. Insufficient corrective action may result in a temporary “cease work” project condition.</p>
--	--

DIVISION 2 – SITEWORK

Section Number	Title
-------------------	-------

Contractor to restore or repair any damaged sidewalks, curbs, utilities, or plant material. The Owner to review repair work with the Contractor and approve prior to final acceptance and payment.

02080	Asbestos Removal
-------	-------------------------

General

All asbestos-containing materials (ACM) are to be removed following proper abatement procedures as outlined in the Occupational Safety and Health Administration's (OSHA) asbestos in Construction Industry Standard 29 CFR 1926.1101. ACM is to be properly contained and disposed of in compliance with all applicable Federal and Arizona regulations.

The asbestos removal contractor will be responsible for the safety and health of its own employees. Compliance with applicable OSHA and EPA regulations will be enforced by the contractor.

The University, or an asbestos consultant acting upon the University's behalf, will insure that all contract specifications, approved work plans and applicable regulations are complied with. The University will visually inspect all removal areas. When required, the Contractor will conduct clearance air monitoring using AHERA guidelines and, if requested, will provide split samples to the University. If contamination is found, the Contractor will be required to perform additional cleaning until acceptable levels are achieved, at no additional cost to the University.

The University or Asbestos Consultant will have the authority to stop work immediately if conditions are not within the specifications for controlling exposure to asbestos.

Description of Work

All fees paid to the contractor shall be based on unit prices determined in advance using a competitive proposal process.

The successful contractor will be required to respond in a timely manner to all requests, within three (3) working days of the notice.

Materials commonly encountered: acoustical ceiling tiles/panels, resilient vinyl flooring materials, transite panels, pipe wrap (lagging) and elbows, asphaltic roofing materials, sprayed or troweled-on wall texture materials.

Applicable Regulations

The contractor shall comply with the regulations specified in section 01120 of the Division 1-General Requirements.

The Contractor shall submit, as part of the close-out requirements, an asbestos removal affidavit.

***** END OF SECTION *****

DIVISION 2 – SITEWORK

Section Number	Title
----------------	-------

02100	SITE PREPARATION
--------------	-------------------------

02110	Site Clearing
-------	---------------

Contractor to restore or repair any damaged sidewalks, curbs, utilities, or plant material. The Owner to review repair work with the Contractor and approve prior to final acceptance and payment.

02115	Selective Clearing
-------	--------------------

02140	Positive Drainage
-------	-------------------

The A/E is responsible for specifying and the Contractor is responsible for maintaining positive drainage away from structures, around all foundation elements within the project boundary. Contractor assumes all liability if positive drainage is not maintained.

02200	EARTHWORK
--------------	------------------

02210	Grading
-------	---------

General

This section defines earthwork as rough and finish grading required to grades to design grades for proper site drainage, lawns, shrub and ground cover beds. This section also includes criteria for building and site storm water retention, which shall be confined on-site in retention areas, ponds or drywells.

Design Standard

Fill:

Foundation wall waterproofing **must** be backfilled within 3 days of placement.

Conceptual grade elevations shall be considered and noted on the schematic site plan and soil fill material shall comply with the following:

- o soil material shall comply with ASTM D 2487 soil classification groups GW, GP, GM, SM, SW and SP;
- o sub-base material shall be specified as naturally or artificially graded mixtures of crushed gravel, stone, slag or sand;
- o base course material shall be specified as naturally or artificially graded mixtures of crushed gravel, or stone, conforming to MAG specification 702, Type B;
- o backfill and fill materials shall be specified as soil free of clay, rock, or gravel larger than 4", debris, waste or other deleterious material;
- o top soil shall be specified as natural, friable, loamy soil, which produces heavy vegetative growth, free from subsoil, weeds, sods, stiff clay and stones larger than 3/4", with a soil Ph not exceeding 8.00 nor less than 6.5, total soluble salts in saturation not exceeding 2,000 parts per million; and,
- o all compaction requirements shall conform to applicable MAG specifications.

Grading and Retention

Calculation and design of site retention and flows shall conform to the most recent City of Flagstaff standards

DIVISION 2 – SITEWORK

Section Title Number

and MAG specifications.

All surface areas shall be graded to drain by natural gravity flow.

Site grades shall direct site water away from all portions of the building, parking lots and walks at slopes that disperses the run-off at a rate that will not allow pooling or ponding.

The use of drywells should only be used as a back-up means of site water retention, and should not be relied upon to satisfy total storm water requirements. NAU does not have a maintenance program to clean and inspect drywells for proper design percolation and sediment removal.

The use of sump type pumps for exterior surface drainage is not allowable.

All grading shall be such that all surface areas will drain by natural gravity flow. Sumps shall not be used for exterior surface drainage disposal. The general guidelines for the amount of slope shall be as follows:

	<u>Grade</u>	<u>Ratio</u>
maximum unsupported cut	100%	1:1
maximum unsupported fill	50%	2:1
maximum practical landscape	40%	2.5:1
maximum lawn slope	33%	3 :1
maximum walk ramp	15%	
maximum handicap ramp	12%	
maximum drive slope	12%	
maximum/ minimum large flat areas	2% to 1%	
minimum landscape or paved areas	1%	

All areas to be planted with grass or ground cover shall receive a minimum of 4" top soil. All finish grades shall be a minimum of 1/2" below adjacent walks, drives, curbs, mow strips and paving.

Any existing site area affected by rough or finish grading activity shall be restored to its original existing condition. Special care should be exercised in design to evaluate any affects new sitework or building will pose on existing site features, retention, travel or aesthetics.

02220 Excavating, Backfilling & Compacting

General

This section includes consideration for any anticipated excavation support systems, including all underpinning, sheeting and tiebacks necessary to protect existing structures, workmen, general public, utilities, pavement, etc. during future project development and the construction process.

Design Standard

All excavation and shoring shall be done in conformance with OSHA Construction Standards for Excavation (29CFR Part 1926.650-652 subpart P) requirements and any other applicable law, rule or statute governing construction excavation and shoring activities on the State of Arizona property.

Any excavation or shoring occurring in close proximity to pedestrian or vehicular circulation; depth and widths greater than 4'; or remaining open longer than 30 calendar days, must be clearly identified on the plans and brought to the attention of the Project Manager by the A/E prior to the start of construction, for appropriate action. The Contractor shall notify the Facilities Development Project Manager who in turn shall notify Facilities Management, Blue Stake and the City of Flagstaff (if applicable) no later than 48 hours prior to any excavation activity;

Any area to be excavated or shored extending six feet or greater below adjacent natural grade, must be

DIVISION 2 – SITEWORK

Section Number	Title
	<p>barricaded or fenced (if appropriate) from pedestrian or vehicular traffic.</p> <p>Excavated material not used for backfill of the project shall be transported off-site at the time it is excavated. Material used for backfilling may be stock-piled within the construction staging area (or other area deemed feasible by NAU).</p> <p>The General Contractor shall be responsible for dust control measures during excavation, stock-piling or transport of material on campus, as required by section 01560.</p> <p>Transport of all excavated material shall be coordinated with the Project Manager, the City of Flagstaff, or Coconino County as applicable. Special time-of-day restrictions in the transport of material may be necessary depending on the project, and should be specified and coordinated with the Project Manager.</p> <p>NAU on occasion has use for good quality excavated material, and the A/E should specify as a bidding option in such cases, direct transport of such material to other NAU project sites or areas.</p> <p>All compaction requirements shall conform to applicable MAG specifications.</p>
02225	<p>Rock Clause</p> <p>Provisions for rock excavation must be included within the bid documents on any project where excavation is required. The A/E shall insert project specific verbiage based on one of the following two options:</p> <ol style="list-style-type: none">1.) Additional Subsurface investigation must be provided by the Owner to indicate rock presence with a high degree of accuracy, in this case the Owner shall be responsible for performing excavation at his cost.2.) Where appropriate a sensible unit price agreement is worked out and rock encounters are paid for individually.
02230	Base Course
02270	Slope Protection and Erosion Control
02280	Soil Treatment
	<p><u>Termite Control</u></p> <p>Termite control is required on all new construction and renovation building projects where there is structure to ground contact. Certificates of treatment application by a licensed professional are required. Submittal required: Record of Treatment that includes the date, time, location of treatment (specific area / grid section), weather conditions, product used. Payment for services shall not be approved until documentation has been submitted and approved, including warranty.</p>

DIVISION 2 – SITEWORK

Section Number	Title
02350	PILES AND CAISSONS
02360	Driven Piles
02380	Caissons

**** END OF SECTION ****

DIVISION 2 – SITEWORK

Section Number	Title
02500	PAVING AND SURFACING

02510 Asphaltic Concrete Paving

General

This section defines general design parameters for paving, curbs and traffic markings. The A/E is required to obtain all information regarding parking stall layout, flow and stall dimensioning from NAU's Parking and Shuttle Services, along with formal written approvals of the design concept from this entity at the completion of the 30%, 60%, and 90% drawings. All handicapped parking stall dimensioning shall be according to "Universal" design, 16' overall 11' space plus 5' access aisle.

Design Standard

In areas where asphalt concrete paving is being proposed for vehicle parking, patching of existing parking areas and new roadways or drives, the design specification shall comply with the following:

The aggregate base course to be 6" minimum in depth, (more as defined on a project specific basis) 100% crushed rock conforming to MAG Specification 702, Type B, compacted per ASTM D1557-78;

Bituminous binder course shall 2" thick, conforming to MAG Specifications Section 710;

Bituminous surface course shall be 2" thick, conforming to MAG Specifications Section 710.

Painted traffic markings to be 4" wide.

No asphaltic concrete curbing or driveway aprons are allowable.

Sealer coat shall be applied after completion of laying of asphalt. A/E to specify time frame and procedures.

Asphaltic concrete pedestrian walkways shall conform to the same MAG and ASTM specification sections cited above, with a 4" aggregate base course, 1" bituminous binder course and 1" surface course.

Dead end driveways are highly discouraged, but if site restrictions mandate this design approach, there shall be a minimum of 20' of unobstructed pull in length; width equal to the driveway.

02515 Unit Pavers

Concrete paving stones are the University preference. 2 3/8" interlocking paving stones, in "N.A.U. Triblend" colors. Unit pavers used in walkways shall have bands of "Finetta" I.P.S. Spacing of bands shall be equal to walkway width. (Reference the pedway for example of the above criteria).

02525 Curbs

Concrete Curbs

Precast Concrete Curbs

Parking bumpers shall be specified for all pavement installations within 2' of existing structures or fences.

DIVISION 2 – SITEWORK

Section Number	Title
----------------	-------

02540	Synthetic Surfacing
-------	---------------------

02545	Surfacing
-------	-----------

Aggregate Surfacing - Chipseal

Quick setting and emulsified asphalt per MAG spec type CRS-2.

Aggregate gradation shall conform to MAG spec table 716-1 for moderate traffic areas and MAG spec Table 716-2 for high traffic areas. ADOT specification CM 11 will be considered as an alternate subject to availability of MAG specification material and credit price.

Submit chip sample for testing prior to application.

The Contractor shall be responsible for providing barricades and appropriate signage for all parking lot entrances. Signs shall read:

"Parking Lot Closed From _____ to
Use Lot # _____"

Loose chips shall be swept and removed within a 24-hour period and again at a later date if required.

Contractor is responsible for protection of all manholes and valve covers. All manholes and valve covers shall be marked with non-permanent orange paint and protected with cardboard (or equally effective material) prior to chip sealing.

Bituminous Surface Course

Bituminous surfacing shall be used only in exceptional cases. Chipseal is the preferred preservation method.

02575	Pavement Repair
-------	-----------------

02580	Pavement Marking
-------	------------------

Roadway and Parking Marking

* * * END OF SECTION * * *

DIVISION 2 – SITEWORK

Section Number	Title
02600	PIPED UTILITY MATERIALS <u>General</u> All electric water sewer and gas subsurface utility pipes shall be buried with metal detector tape. Such tape shall be buried a minimum of 12" and a maximum of 16" below grade.
02605	Manholes and Cleanouts
02610	Pipe and Fittings Cast-Iron Pipe Ductile Iron Pipe Mineral Fiber Reinforced Cement Pipe Plastic Pipe Steel Pipe Vitrified Clay Pipe
02640	Valves and Cocks Valve Boxes
02660	Water Distribution All water systems shall be protected from main City of Flagstaff supply by backflow preventers. All backflow preventer installations shall be required to be inspected by certified backflow preventer inspectors.
02665	Domestic Water Systems <u>Fire Water Systems</u> Fire hydrant flow tests are required with written test results submitted, prior to payment. Tests shall be paid for by the Contractor, performed and witnessed by the Fire Marshal, NAU Risk Management and NAU Project Manager. <u>Heating Water Systems</u>
02675	Disinfection of Water Distribution Systems

*** * * END OF SECTION * * ***

DIVISION 2 – SITEWORK

Section Number	Title
02680	Fuel Distribution

02685	Gas Distribution System
-------	-------------------------

NAU is considered an Owner Operator and all ACC regulations apply.

In addition to the requirements listed below, the Contractor shall follow the Northern Arizona University Gas Distribution Line Instructional Guide, available at NAU Facility Services. www.nau.edu/~facman.

All electric water sewer and gas subsurface utility pipes shall be buried with metal detector tape. Such tape shall be buried a minimum of 12" and a maximum of 16" below grade.

All underground pipe shall be:

- o Schedule 40 black iron steel, factory coated and protected with cathodic protection - U.S. domestic made pipe.
- o All gas lines into building need to have insulating unions installed to isolate building pipe from underground piping.
- o All underground pipe shall be buried a minimum of 24" deep with alternate shading and with metal detector tape. Tape shall be installed a maximum of 6" below grade.
- o Any abandoned gas line shall be removed or purged by the contractor. Any such removal must be noted and dated on the as-builts. The contractor shall submit a dated written statement of purging.

Submittals

- o Mandatory: 30 days prior notice of any construction (in writing) involving gas pipe line main distribution systems with proposed plans involving gas distribution system.
- o Installer of gas system must provide to the Arizona Corporation Commission (ACC) and the University, paperwork showing the welder's certification, the welding procedures to be used on installation and verification that the welder has used these procedures within the past six months, and test results confirming the procedures to be used.
- o All pressure tests on lines, shading of ditches, coating of pipes, cathodic protection, tracer lines and open ditches must not be removed or covered until the ACC has been notified and performed visual inspection.
- o As-built prints shall be provided showing the accurate location of all utilities.

02695	Steam Distribution System
-------	---------------------------

Northern Arizona University maintains two central plants on campus, one supplying steam and chilled water to north campus buildings and one supplying 250° HTHW (High Temperature Hot Water) to south campus buildings. In addition, there are several buildings with natural gas fired furnaces or hot water boilers.

*** * * END OF SECTION * * ***

DIVISION 2 – SITEWORK

Section Number Title

02700 SEWERS AND DRAINAGE

02720 Storm Sewage Systems

The hydraulic grade line shall be computed at all junctions. At all inlet junctions the hydraulic grade line shall be below the flow depth limits per MHDUD (City of Flagstaff Manual for hydraulic Design for Urban Drainage). Hydraulic grade lines shall be shown on the construction plans.

The design and capacity flows shall be shown on the storm drain profile for each reach of the system.

The minimum size for drain pipe shall be 18" or equivalent arch pipe.

All storm drains shall be designed to have a self-cleaning minimum velocity of 3fps at the design storm.

Horizontal and vertical pipe separation shall be per manufacturer's specification with a minimum of ___ feet.

The minimum cover for storm drains shall be one foot as measured to subgrade, or to finish grade if no subgrade is involved.

Trench details for storm drains shall comply with MAG specifications.

Manhole spacing shall be at a maximum of 500 feet and at horizontal deflections per the table below:

Pipe Size	Deflection	Manhole Required
18" to 42"	0° to 22 1/2°	No
18" to 42"	> 22 1/2°	Yes
> 42"	0° to 45 °	No
>42"	> 45°	Yes

Any vertical deflections will require manholes. Manholes will be placed as close as possible to the point of deflection, with allowance for manufactured bends etc. If the manhole cannot be placed at the point of deflection, then it should be located immediately upstream from the deflection.

02730 Sanitary Sewage Systems

02760 Restoration of Underground Pipelines

02762 Inspection of Pipelines

02764 Sealing Existing Pipelines

02780 Power and Communications

02785 Electrical Power Transmission

02790 Communication Transmission

* * * END OF SECTION * * *

DIVISION 2 – SITEWORK

Section Number **Title**
02800 **SITE IMPROVEMENTS**

02810 Irrigation Systems

Trenching: Cover Requirements:

All pipe and wire under pavement	24"	
Pressurized Lines	18"	
Non-pressurized lines	12"	
Non-pressurized drip laterals	8"	
Control Wire		18"

Lines bordering curbs and sidewalks shall be held 12" away to allow for maintenance and access to the lines.

Backfill around and over pipes shall be with sandy soil free from rocks over 1/8" in diameter. Where existing soil does not meet this requirement, sandy soil shall be imported for backfilling.

Pipe and control wiring and tubing under walks, roads and other hard surfaces shall be installed in schedule 40 sleeves that are two times the size of the pipe. Sleeves shall extend a minimum of 12" beyond the hard surface.

Heads, bubblers, and drip lines shall maintain a minimum of 2' 0" setback from walks, drives or building faces. Special care shall be utilized in design to avoid the possibility of wind driven mist from wetting paving and building surfaces.

Pipe and Fittings

All main lines shall be looped whenever possible so as to improve pressure and flow.

All pipe used for main lines and auxiliary lines shall be schedule 40 PVC pipe with ratings printed on pipe.

All fittings shall be schedule 40, pressure rated, PVC fittings.

Fittings between the auxiliary (lateral) line and any sprinkler head or hose bib shall consist of a rigid PVC full circle swing joint, "Lasco" brand or pre-approved equal.

Specifications for piping shall include standards that all piping shall be free from cracks, holes, foreign materials, blisters, inside bubbles, wrinkles, and dents.

If pipe is stored outside it shall be protected from direct sunlight.

No galvanized nipples, elbows, or other fittings shall be used with PVC pipe installations.

PVC joints shall be glued according to manufacture's recommendations.

Glued joints shall set for 24 hours before pressure is applied to lines.

Control Wires

Electronic controller cable to be solid copper wire, UL approved for direct burial, minimum gauge 14 UV for runs under 1000 L.F., 12 UF for runs over 1000 L.F. Control wires must be buried at least 18" below finish grade.

DIVISION 2 – SITEWORK

Section Number	Title
----------------	-------

Electric control wires shall be color coded so that neutrals are white, grass areas are red, shrub areas are blue, flower beds are green and drip irrigated areas are brown.

Lawn, shrub, flower beds, desert and drip areas shall be valved separately and have separate stations on the time clock.

All connections to valves and all splices shall be made with "SNAP-TITE" connectors and PT-55 sealer (RAINBIRD), or equal.

All splices shall be made in valve boxes.

Valves

Avoid locating valves in areas where curbs and walks come together.

Main valves should be located, when possible, in a grassed area, five feet from sidewalks curbs, or other traffic areas.

Valves shall have a minimum size of 1".

Valve boxes shall be set at finished grade with valve stems 4" below top of the box. Each valve box or group of valves shall have a hose bib on the pressure side of the valve.

Where possible, control valves shall be manifolded together.

All valves shall be placed in valve boxes so to allow access for servicing.

3" of gravel shall be placed under all valves (electric, gate and sectional).

Clocks

Clocks shall be RAINBIRD "MAXI" computer control compatible and shall be capable of maxi-operation. Rainbird, ISC, or SBM 1230, electro-mechanical system.

Clocks shall be mounted outside the buildings or any other proximate built structure.

Heads

Heads for lawn areas less than 25 feet wide shall be Hunter I 10 or Hunter I 20 or equal.

Heads for strips and shrubs shall be Rainbird 1800 series, Rainbird 1400/1500 bubblers or equal.

Heads for open areas 25 feet or wider shall be Hunter I 25 or equal.

Heads for large areas with few trees shall be RAINBIRD SAMS or Hunter I40.

Placement of heads shall be influenced by prevailing wind direction, location of mounds and placement and location of trees.

Provide diagrams for all head installation.

All lines shall be flushed before the heads are installed.

DIVISION 2 – SITEWORK

Section Number	Title
----------------	-------

A non-fading, weather resistant copy of the irrigation diagram and controller name-label shall be affixed to the inside of the controller cabinet door. The irrigation diagram shall show all valves operated by the controller, valve sizes and type of plantings irrigated.

Backflow Prevention

Backflow preventers shall be reduced pressure type and shall be installed at all connections to water distribution mains. Preferred manufacturers are FEBCO, WATTS or pre-approved equal.

All backflow preventers shall be assembled with pipe fittings and risers of galvanized steel.

Valves and drains shall be placed so the entire system may be winterized.

*** * * END OF SECTION * * ***

DIVISION 2 – SITEWORK

Section Number	Title
02830	FENCES AND GATES <u>Chain Link Fences and Gates</u> <u>Ornamental Metal Fences and Gates</u> The University has a standard design for the masonry pillar/ornamental iron fence that surrounds the campus. The A/E shall obtain this design standard from the Facilities Development project manager for projects which require additions to this fence. The University has a standard design for the masonry pillar/ornamental iron fence that surround the campus. The A/E shall obtain this design standard from the project manager for projects that require additions to this fence. <u>Wood Fences and Gates</u>
02840	Walk, Road and Parking Appurtenances <u>Bicycle Racks</u> <u>Guardrails</u> <u>Parking Barriers</u> <u>Parking Bumpers</u> <u>Signage</u> Prior to specifying exterior or interior signage the Professional Consultant must request a copy of the NAU Signage Policy Manual.
02860	Playfields and Equipment <u>Recreational Facilities</u>
02870	Site and Street Furnishings <u>Trash and Litter Receptors</u> <u>Tree Grates</u>

* * * END OF SECTION * * *

DIVISION 2 – SITEWORK

Section Number Title

02900 LANDSCAPING

General

All plantings shall be guaranteed by the Contractor for a minimum of one year after substantial completion

All specified planting materials shall be of species that has a proved history of resilience in this Northern Arizona locale. Preference shall be given to designs that center around a xeriscape approach and utilize drip irrigation

Planting List

The following trees and shrubs have been identified and labeled as focus plant material to be utilized in campus planting.

Trees

Acer Platanoides	Red Maple
Malus	Flowering Crabapple
Pinus nigra	Australian Black Pine
Picea Pungens	Colorado Blue Spruce
Populus Tremuloides 'Kaibab'	Kaibab Aspen
Robina pseudoacacia	Black Locust

Shrubs

Fallugia paradoxa	Apache Plume
Juniperus spp	Juniper
Mahonia aquifolium	Oregon Grape
Pinus mugo mugo	Dwarf" Mugo Pine
Potentilla Fruticosa	Potentilla
Rhus spp	Sumac
Ribes spp	Currant
iburnum Opulus	Snowball Viburnum

The following trees and shrubs may be utilized on campus with the approval of the Director of Facilities Services and the Grounds Supervisor

Acceptable Plant Material (Trees)

Abies Concolor	White Fir
Abies Lasioarpa Arizonica	Corkbark Fir
Acer ginnala	Amus Maple
Acer Saccharum	Sugar Maple
Acer Negundo	Boxelder
Acer Saccharinum	Silver Maple
Betula Pendula	European White Birch
Fraxinus Americana	American Ash
Catalpa spp	Catalpa

DIVISION 2 – SITEWORK

**Section
Number** **Title**

**Section
Number** **Title**

Fraxinus Pennsylvanica	Green Ash
Gleditsia Tracanthos	Honeylocust
Picea Abies	Norway Spruce
Picea Engelmannii	Englemann Spruce
Pinus Aristata	Bristlecone Pine
Pinus Flexilis	Limber Pine
Pinus Sylvestris	Scotch Pine
Platanus spp	Sycamore
Populus Tremuloides	Quaking Aspen
Prunus spp	Flowering Plum
Prunus spp	Flowering Cherry
Pseudotsuga Menziesii	Douglas Fir
Pyrus Calleryana	Bradford Flowering Pear
Quercus Gambelli	Gambel Oal
Quercus Rubra	Northern Red Oak
Salix matsudana	Globe Willow
Sequoidendron Giganteum	Giant Sequoia
Tilia spp	Linden

Acceptable Plant Material (Shrubs)

Agave spp	Agave
Amelanchier spp	Serviceberry
Amorpha fruticos	Indigo Bush
Berberis thunbergii	Japanese Barberry
Chamaebatiaria millifolium	Fernbush
Cowania Mexicana	Common Cliffrose
Forsythia Intermedia	Dwarf Forsythia
Ligustrum Vulgare	Privet
Locicera Involucrata	Twinberry Honeysuckle
Robinia neomexicana	New Mexico Locust
Rosa spp	Rose
Rosa woodsii	Wild or Woods Rose
Spiraea spp	Spirea
Yucca spp	Yucca

Acceptable Plant Material (Groundcovers)

Scientific Name

Common Name

Delosperma nubigenum	Ice Plant
Lonicera arizonica	Arizona Honeysuckle
Partheocissus quinquefolia	Virginia Creeper
Sedum spp.	Stonecrop

Acceptable Plant Material (perennial flowers)

Scientific Name

Common Name

Archillea spp.	Yarrow
Berlandiera lyrata	Chocolate Flower
Campanula Glomerata	Clustered Bellflower
Cetnranthis ribber	Red Valerian
Chamaemelum Nobile	Chamomile
Clematis spp	Clematis
Coreopsis spp	Coreopsis

DIVISION 2 – SITEWORK

Section Number	Title
	Eschscholzia californica California Poppy
	Gaillardia grandiflora Blanket Flower
	Sempervivum tectorum Hens and Chickens
	Geum triflorum Old Man's Whiskers
	Hemerocallis spp DayLily
	Ipomopsis aggregate Skyrocket
	Iris spp Bearded Iris
	Linum perenne Blue Flax
	Lupinus spp Lupine
	Kniphofovia uvaria Red hot Poker
	Oenothera caespitosa Tuft Evening Prim-rose
	Oryzopsis hymenoids Indian Rice Grass
	Penstemon spp. Beardtongue
	Phlox spp Phlox
	Potentilla spp. Cinquefoil
	Ratibida columnifera Mexican Hat
	Salvia spp Sage
	Thymus spp. Thyme
	Zinnia grandiflora Prairie Zinnia

Acceptable Plant Material (Flowers)

The flower list subject to approval of the Manager of Planning and Design and the Grounds Supervisor.

02910 Shrub and Tree Transplanting

All trees and shrubs shall be container grown, not balled and burlap, unless otherwise approved by NAU Grounds Department.

02920 Soil Preparation

Topsoil

Topsoil shall be friable, loam topsoil, free from sticks, stones over 1" in diameter, roots, refuse, noxious weeds or any other material toxic to plant growth.

Shall have:

- o Loam and soil texture (USDA classification)
 - 30% to 50% sand
 - 10% to 25% clay
 - 30% to 50% silt
- o PH. - 6.0 - 7.5
- o Electrical conductivity (ec) - 4.0 milliohms or less per centimeter as measured on the saturation extract.
- o Sodium absorption ratio of less than 5 as measured on the saturation extract.

Prior to the delivery the Contractor shall furnish the University at no additional cost, a numerical analysis and test from a soils laboratory which will include:

- Nitrogen
- Phosphorus
- Potassium
- Electrical conductivity (ec)
- Sodium absorption

DIVISION 2 – SITEWORK

Section Number	Title
----------------	-------

PH	Percentage of sand, silt, clay, organic matter, water holding capacity
----	--

Landscape or planting areas shall not be cultivated when they are so wet as to cause excessive compaction or so dry as to cause excessive dust or the formation of large clods.

If imported soil is specified the existing soil shall be scarified to a minimum depth of 8 inches prior to placing topsoil. All clods and rocks over 1 inch in diameter, within 6 inches of the surface, shall be removed and disposed of off site. The thickness of the topsoil shall be at least 4 inches.

All in-place soil and topsoil shall be free from nut grass, refuse, roots, noxious weeds, or any material toxic or a hinderance to plant growth.

Unless otherwise specified, all in-place and/or imported soil will be prepared and conditioned as topsoil to meet the following minimum specifications:

- o PH shall not exceed 7.5 or lower than 6.0
- o Electrical conductivity (ec) shall be less than 4.0 milliohms per centimeter as measured on the saturation extract.
- o Sodium absorption ratio of less than 5 as measured on the saturation extract.
- o Shall contain approximately 1.5%, by dry weight, organic matter either natural or added.
- o Soil gradation shall be in accordance with section 795.2 of the Uniform Standard Specifications for Public Works Construction, Maricopa Association of Governments, 1979 edition.
- o Any use of manure as a soil conditioner is not acceptable.

All planted areas shall be conditioned by spreading evenly, over the areas, and thoroughly incorporating (rototilled) into the soil to a depth of 6 inches the following material, per 1000 square feet:

- o 20 lbs of 6-20-20 commercial fertilizer.
- o 3 cubic yards of nitrogen stabilized amendment derive from redwood sawdust, fir sawdust or finely ground bark.

02930	Lawns, Grasses, and Wildflowers
-------	---------------------------------

No more than 10% of the area around newly constructed facility shall be turf or other type of water intensive vegetation.

Lawns shall be specified only where maintainable with full normal access (no inner courtyards not directly accessible from outside) for irrigation, mowing, fertilizing, and pest control operations.

Lawn areas shall be designed open and clutter free, as far as practical, shrubs and ground cover areas shall be separated by concrete, exposed aggregate, 6" x 6" or greater treated timbers or occasionally brick headers, their tops being 1/2 inch above sod/soil level.

Lawn grass shall not be used in any planting strip less than 36" wide unless it has an extension of a continuous larger area.

Lawn soil surfaces shall be constructed 1/2 inch below walks, curbs, mow strips or other adjacent paving.

Any valve boxes installed in turfing areas shall be made flush with the **finish** grade not turf height.

Lawns may be established cut sod or by hydroseeding. In either case the soil shall be thoroughly rototilled and leveled to receive the grass.

Single isolated posts in lawn areas shall be fitted with a concrete mow strip at least 6 inches wide around the post.

DIVISION 2 – SITEWORK

Section Number	Title
----------------	-------

Hydroseeding

The preferred grass seed mix is a perennial rye/bluegrass mix. Submit species for approval.

Any wildflower seed mix shall be submitted to the NAU Facilities Management Grounds division prior to specifying. All specified hydroseeding must be in place prior to August 1.

Sodding

Sod will be a bluegrass/perennial rye mix. It will come from an area with similar climate and soil conditions to the University. Sod grown on a sandy loam soil will not be accepted. Preferred supplier of sod is Bar-T-Bar from Long Lake, Arizona.

All sod must be in place prior to September 1.

02950	Trees, Plants and Ground Covers
-------	---------------------------------

Temporary Protection

Provide temporary fencing, barricades or guards to protect from damage existing trees, lawn, and other plants which are designated to remain on site.

Protect root systems by not storing construction materials, debris, or excavated material within five (5) feet of the drip line of the tree (outer perimeter of the branches). Do not permit vehicle traffic within stated area and restrict foot traffic to prevent excessive compaction of the soil over root systems.

Repair and Replacement of Trees, Shrubs and Lawn

Repair trees, shrubs and lawns damaged by construction in a manner acceptable to the Landscape Architect and/or the Facilities Management Grounds Supervisor. Make repairs promptly after damage occurs to prevent progressive deterioration of damaged trees, shrubs, and lawns.

Remove and replace dead and damaged trees, lawns, and shrubs, which are determined by the Grounds Supervisor to be incapable of restoration to normal growth patterns.

Provide new trees of same size and species, unless such plant is on the "DO NOT PLANT" list. Plant and maintain as specified under landscaping section of the specifications. For any trees requiring replacement due to neglect by the contractor that have a caliper greater than 4", a penalty of \$1,000.00 per tree will be assessed.

Trees and Shrubs

All specified tree and shrub plant material must be in place prior to August 1.

All plant materials used shall be of types proven hardy for the area and situation. New, novel or "different" plants shall be restricted to a bare minimum. All plants shall be healthy, true to name and full size of specifications (no recent shifts to larger container).

The minimum caliper size for new trees shall be 2 inches.

Trees planted in lawns shall be provided with 24 inches of bare, sod free soil beyond and around the full circle of the tree. This area shall also be depressed (dish shaped) to help deep watering of the tree.

Deciduous trees shall be planted no closer than 8 feet from any walk or drive and evergreen trees planted no closer than 2 feet greater than the anticipated mature radius of branching.

DIVISION 2 – SITEWORK

Section Number	Title
----------------	-------

Trees planted in rows shall be uniform in size and shape.

Trees and shrubs shall not be planted until all construction working the area has been completed, final grades established, the planting areas properly graded and prepared as specified.

Dig plant pocket for trees a minimum of 24" wider and 6" deeper than root ball, unless otherwise specified.

Dig plant pocket for shrubs a minimum of 12" wider and 6" deeper than root ball, unless otherwise specified.

Loosen subsoil to a depth of 4". Loosen earth on sides of pocket to break the glaze caused by digging.

Set plants at finished grade.

Fill prepared soil to 1/2 the depth of ball, pack firmly, and settle with water.

If balled and burlapped, loosen and remove burlap and all lacing from upper two-thirds of ball. Backfill with prepared soil which, after compaction, is flush with ground level.

Cover plant pocket area with 3" to 4" of mulch.

Prune, wrap and brace as specified.

02970

Landscape Maintenance

The watering, fertilizing and treating of all existing trees, lawns, shrubs and other plant materials located within the contract limit line or construction fence of the project, will be the responsibility of the Contractor for the duration of the maintenance period. Specifications and notes on the landscape drawings shall require the Contractor to maintain and accept responsibility for all plant material for a minimum of 90 days or through to final acceptance of the work, whichever is longer.

Maintenance shall begin immediately after each portion of lawn and each plant is planted and shall continue in accordance with the following requirements:

- o Lawns that have been planted shall be protected and intensively maintained by watering, mowing, fertilizing and re-planting as necessary through a minimum of 90 calendar days or longer if necessary to establish a uniform stand of the specified grasses and until acceptable.
- o New planting and groundcovers shall be protected and maintained until the end of the lawn maintenance period or until final acceptance, whichever is longer. Maintenance shall include water, fertilizing, weeding, cultivating, mulching, tightening and repairing guys, removal of dead materials and resetting plants to proper grades.
- o The Warranty period for all plant materials shall be a minimum of one calendar year.

*** * * END OF SECTION * * ***