

DIVISION 8 – OPENINGS

Section Number	Title
08 00 00	OPENINGS
08 10 00	DOORS AND FRAMES
08 11 00	Metal Doors and Frames
08 11 13	Hollow Metal Doors and Frames
08 11 19	Stainless-Steel Doors and Frames
08 14 00	Wood Doors
08 17 00	Integrated Door Opening Assemblies
08 40 00	ENTRANCES, STOREFRONTS, AND CURTAIN WALLS
08 41 00	Entrances and Storefronts
08 41 13	Aluminum-Framed Entrances and Storefronts
08 41 23	Steel-Framed Entrances and Storefronts
08 42 00	Entrances
08 42 29	Automatic Entrances
08 44 00	Curtain Wall and Glazed Assemblies
08 50 00	WINDOWS
08 51 00	Metal Windows
08 51 66	Metal Window Screens
08 52 00	Wood Windows
08 52 16	Plastic-Clad Wood Windows
08 70 00	HARDWARE
08 80 00	GLAZING
08 81 00	Glass Glazing

DIVISION 8 – OPENINGS

Section
Number
08 00 00

Title
OPENINGS

Part 1 - General

Doors and door hardware are to be installed only by qualified persons and all work must meet codes referenced in Division 1. No exceptions will be made to the hardware listed below for use in any construction without prior testing, evaluation and approval by appropriate departments within Owner's Facility Services department (FS).

Part 2 – Products

All doors, hardware, openers, etc. shall be specified as institutional grade throughout.

All hardware submittals shall be routed through Owner's Building Access Services department for review and approval prior to purchase.

Part 3 – Execution

Final acceptance of any hardware installations shall be subject to approval by Owner's Building Access Services department.

08 10 00
08 11 00

DOORS AND FRAMES
Metal Doors and Frames

Part 1 - General

Doors and frames shall be commercial heavy-duty quality. Minimum door thickness shall be 1-3/4" thick. Interior doors shall comply with SD1-100, Grade II, heavy duty, minimum 16-gauge faces. Exterior doors shall comply with SD1-100 Grade III extra heavy duty, minimum 16-gauge faces.

All exterior doors shall have thresholds, closures, weatherstripping, and padded stops.

At least one section of an exterior door assembly (main ingress and egress) shall have an electric automatic door opener, button activated on both sides. Interior and exterior kickplates are required of all doors that are subject to high traffic. **High traffic doors commonly defined as public restroom, kitchen/ industrial, building entry, and classrooms.**

Part 2 - Products

Door Frames

In new construction all frames shall be welded. Knock-downs may be acceptable in building renovation work, pending Owner's Building Access Services approval

DIVISION 8 – OPENINGS

Section Number	Title
	<p>of submittals and final installation. An inspection of anchoring must be made prior to drywall or closing up of walls.</p> <p>Frames shall have wall anchors a maximum of 16" o.c. per jamb. All door frames will be steel. Exterior door frames will be 14 gauge and protected from rust.</p> <p>Door frames shall be factory pre-assembled with mitered fully welded joints ground smooth and delivered to the job site with spreaders. If knock-down and two-piece frames are unavoidable and approved in advanced by Owner's Building Access Services, it must have quality standards for securing and finishing these frames. Shop priming is required.</p> <p>All frames shall be delivered prior to masonry construction. All frames in masonry walls shall be grouted full with portland cement grout. Gypsum grout is not permitted.</p> <p>There shall be seamless end channel closure pieces at door heads.</p> <p><u>Doors</u></p> <p>All external doors will be 16-gauge steel with vertical steel rib stiffeners and reinforced for all door hardware. Internal doors shall be 16-gauge, or may be solid core wood.</p> <p>Where doors are to be used as part of an acoustical barrier assembly, they shall be rated a minimum of STC 33.</p> <p>Doors used as a normal means of ingress and egress shall have either vision panels or adjacent sidelights (where allowable by fire ratings).</p> <p>Doors shall have a minimum of 3 heavy duty industrial type hinges per door.</p> <p>Doors and frames shall have a spray applied finish.</p> <p>There shall be door stops on all installations and closures if doors open into a rated space.</p> <p><u>Part 3 – Execution</u> N/A</p>
08 14 00	<p>Wood Doors <u>Part 1 - General</u></p>

This section applies to interior applications. Endangered or limited tree species

DIVISION 8 – OPENINGS

Section
Number

Title

are not allowable for wood door veneers. Doors receiving painted finishes are limited to low cost species (birch, maple, etc.). Welded hollow metal frames should be utilized.

Part 2 - Products

Wooden doors are acceptable only for interior usage, must be solid core, and have adhesives that are 100% waterproof. Hollow core doors shall not be used and existing hollow core doors shall not be re-used.

All doors shall be solid core flush with veneer faces, commercial heavy-duty minimum grade, 1-3/4" thick. Minimum width to be 3'-0". Maximum height to be 7'-0". **3'0" x 7'0" doors are the Owner's standard. Exceptions must be reviewed and approved by Owner's Building Access Systems. Specified requirements for non-standard doors are available through Owner's Carpentry department if approval is granted.**

Formaldehyde off-gassing rates must be less than .03 milligrams per square foot of surface/hr in accordance with ASTM D5116-90.

All doors that are warped after installation, shall be replaced prior to substantial completion. Substantial completion cannot be achieved if one hour rated corridors' integrity is compromised by warped doors.

Where doors are to be used as part of an acoustical barrier assembly, they shall be rated a minimum of STC 33.

Door receiving a stained finish shall have premium quality face veneers, minimum thickness 1/16". Doors receiving a paint finish shall be smooth, faux wood grain, or pre-primed skin.

Doors used as a normal means of ingress and egress shall have either vision panels or adjacent sidelights (where allowable by code) in metal frames.

Doors shall have a minimum of 3 ball bearing full mortise type hinges per door.

All doors subject to heavy traffic shall have kickplates both sides.

Part 3 - Execution

Inspection

The Contractor is required to have Owner's Carpentry department inspect and approve door installation after doors and jams have been installed and prior to casing installation. Failure to have approval will require the Contractor to remove the casing for inspection at Contractor's expense.

DIVISION 8 – OPENINGS

**Section
Number**

Title

Wood frame pre-hung doors installed in renovations to existing buildings

All pre-hung interior door assemblies shall be inspected after hanging, and before the casing is applied. Assemblies which do not meet specifications shall be re-hung and re-inspected before casing is applied.

All paint grade doors shall be pre-primed.

Doors must be standard sizes whenever possible (i.e.: 6'-8" tall, 2'-0", 2'-4", 2'-6", 2'-8" or 3'-0" wide)

Installation

All pre-hung door assemblies shall be fastened to the framing with a minimum of 5 groups of 2, 2 ½" nails on both hinge and jamb sides.

Both jamb and hinge sides will use a minimum of three shimmed contact points.

One screw per hinge will penetrate the rough opening framing by at least 1"

Hinge, jamb, and head legs of the pre-hung assembly will be straight to within 1/8" deviation along their total length.

Hinge and jamb legs will be installed to within 1/8" of plumb.

Closed doors shall show a reveal of 1/8" on all three sides of the jamb unit, and ½" to ¾" above the finished flooring.

Doors shall open, close, and latch without excessive force.

08 17 00

Integrated Door Opening Assemblies

Part 1 - General

Smoke and draft assemblies shall comply with IBC and IFC (or the most current building and fire codes).

Part 2 – Products

N/A

Part 3 – Execution

N/A

DIVISION 8 – OPENINGS

Section Number	Title
08 40 00	ENTRANCES, STOREFRONTS, AND CURTAIN WALLS
08 41 00	Entrances and Storefronts
08 41 13	Aluminum-Framed Entrances and Storefronts

Part 1 - General

Aluminum entrance section hardware shall meet all requirements in this section.

Part 2 – Products

All window openings shall be thermal broke, sill flashed to exterior, and flashing end dammed. All exterior glass shall be insulating glass, except vestibule doors and windows.

Bottom of window rough opening shall be a minimum of 12” above grade, slabs on grade, or other horizontal surfaces.

Glass manufacturer shall provide a written warranty that shall guarantee insulating glass units for a period of ten years.

Part 3 - Execution

Aluminum entrances and storefronts shall pass water leak testing prior to substantial completion and prior to payment for materials and labor. Test area shall include perimeter caulk joint. All failed windows shall be retested until they pass. All retesting and associated costs shall be paid for by the Contractor.

Weatherstripping for exterior doors shall be continuous at head, jambs, and door bottoms.

All aluminum doors will be wide stile with a mid-rail.

08 41 23	Steel-Framed Entrances and Storefronts
----------	--

Part 1 - General

Steel entrance section hardware shall meet all requirements in this section.

Part 2 – Products

Glass manufacturer shall provide a written warranty that shall guarantee insulating glass units for a period of ten years.

Part 3 – Execution

Steel entrances and storefronts shall pass water leak testing prior to substantial completion and prior to payment for materials and labor. Test area shall include perimeter caulk joint. All failed windows shall be retested until they pass. All retesting and associated costs shall be paid for by the Contractor.

DIVISION 8 – OPENINGS

Section Number	Title
	<p>All window openings shall be thermal broke, sill flashed to exterior, and flashing end dammed. All exterior glass shall be insulating glass, except interior vestibule doors and windows.</p> <p>Weatherstripping for exterior doors shall be continuous at head, jambs, and door bottoms.</p>
08 42 00	Entrances
08 42 29	<p>Automatic Entrances</p> <p><u>Part 1 - General</u></p> <p>All automatic entrance doors shall comply with all door and hardware specifications contained in Division 8. Hardware shall meet all requirements in section 08 70 00.</p> <p><u>Part 2 – Products</u></p> <p>Glass manufacturer shall provide a written warranty that shall guarantee insulating glass units for a period of ten years.</p> <p><u>Part 3 – Execution</u></p> <p>Entrance doors shall pass water leak testing prior to substantial completion and prior to payment for materials and labor. Test area shall include perimeter caulk joint. All retesting and associated costs shall be paid for by the Contractor, via deduct change order.</p> <p>Weatherstripping for exterior doors shall be continuous at head, jambs, and door bottoms.</p>
08 44 00	Curtain Wall and Glazed Assemblies
	<p>Part 1 - <u>General</u></p> <p>This section applies to exterior glazed curtain wall systems and storefronts (also used as fixed window systems).</p> <p><u>Part 2 - Products</u></p> <p>Curtain wall systems shall utilize 1", dual pane insulated glass, fully tempered.</p> <p>Steel or hollow metal type system shall be used. Aluminum alloy extrusions are not acceptable in areas that support or are directly adjacent to door openings.</p> <p>"Kynar 500" or equal shall be specified for painted finishes, spray applied.</p> <p><u>Part 3 - Execution</u></p> <p>Entrances and storefronts shall pass water leak testing prior to substantial</p>

DIVISION 8 – OPENINGS

Section Number	Title
	<p>completion and prior to payment for materials and labor. Test area shall include perimeter caulk joint. All failed windows shall be retested until they pass. All retesting and associated costs shall be paid for by the Contractor.</p> <p>Bottom of window rough opening shall be a minimum of 12" above grade, slabs on grade, or other horizontal surfaces.</p> <p>Glass manufacturer shall provide a written warranty that shall guarantee insulating glass units for a period of ten years.</p> <p>Maximum air infiltration shall not exceed 0.05 cfm per gross square foot of exterior area, when tested in accordance with ASTM E 283, section 4.3.</p> <p>Where doors are utilized in curtain wall assemblies, at least one section of an exterior door assembly (main ingress and egress) shall have an electric automatic door opener, button activated at the swing side, interior and exterior. All ADA activation buttons shall be hard wired except as approved by Building Access Services.</p>
08 50 00	WINDOWS
08 51 00	Metal Windows
	<u>Part 1 – General</u> <p>Aluminum or any other type of metal sash windows shall have thermal breaks, sill flashed to the exterior, and flashing end dammed. All exterior glass shall be insulating glass.</p> <p><u>Part 2 – Products</u> Glass manufacturer shall provide a written warranty that shall guarantee insulating glass units for a period of ten years.</p> <p><u>Part 3 - Execution</u> All windows shall pass water leak testing prior to substantial completion and prior to payment for materials and labor.</p> <p>Test area shall include perimeter caulk joint. All failed windows shall be retested until they pass. All retesting and associated costs shall be paid for by the Contractor.</p>
08 51 66	Metal Window Screens
	<u>Part 1 – General</u> <p>For residence halls, a separate window screen shall be installed, with a frame profile of 3/8" x 1 inch.</p>

DIVISION 8 – OPENINGS

Section Number	Title
	<u>Part 2 – Products</u> N/A
	<u>Part 3 – Execution</u> N/A
08 52 00	Wood Windows
08 52 16	Plastic-Clad Wood Windows
	<u>Part 1 – General</u> Vinyl clad wooden windows are the preferred specified product. All exterior glass shall be insulating glass.
	<u>Part 2 – Products</u> Glass manufacturer shall provide a written warranty that shall guarantee insulating glass units for a period of ten years.
	<u>Part 3 - Execution</u> All windows shall pass water leak testing prior to substantial completion and prior to payment for materials and labor. Test area shall include perimeter caulk joint. All failed windows shall be retested until they pass. All retesting and associated costs shall be paid for by the Contractor.
08 70 00	HARDWARE
	<u>PART 1 - GENERAL</u>
	1.1 SUMMARY
	A. Section includes:
	1. Mechanical door hardware for the following:
	a. Swinging doors.
	b. Sliding doors.
	2. Cylinders for door hardware specified in other Sections.
	3. Electrified door hardware.
	4. Padlocks
	B. Related Sections:
	1. Section 08 11 13 "Hollow Metal Doors and Frames" for astragals provided as part of labeled fire-rated assemblies and for door silencers provided as part of hollow-metal frames.
	2. Section 08 41 13 "Aluminum-Framed Entrances and Storefronts" for door silencers provided as part of aluminum frames.
	3. Section 08 10 00 " Doors and Frames" for access door hardware,

DIVISION 8 – OPENINGS

Section
Number

Title

except cylinders.

4. Section 08 70 00, 2.16 "Overhead Stops and Holders" for door hardware provided as part of overhead door assemblies.
5. Section 10 22 13 "Wire Mesh Partitions" for door hardware for doors in wire mesh partitions, except cylinders.
6. Section 28 06 10 "Schedules for Access Control" for electric locks, exit devices and strikes provided in 08 70 00.
7. Section 08 42 29 "Automatic Door Operators".
8. Section 06 41 93 "Cabinet and Drawer Hardware".

1.2 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated. Include construction and installation details, material descriptions, dimensions of individual components and profiles, and finishes.
- B. Shop Drawings: Details of electrified door hardware, indicating the following:
 1. Wiring Diagrams: For power, signal, and control wiring and including the following:
 - a. Details of interface of electrified door hardware and building safety and security systems.
 - b. Schematic diagram of systems that interface with electrified door hardware.
 - c. Point-to-point wiring.
 - d. Risers.
 - e. Elevations doors controlled by electrified door hardware.
 2. Operation Narrative: Describe the operation of doors controlled by electrified door hardware.
- C. Other Action Submittals:
 1. Door Hardware Schedule: Prepared by or under the supervision of Installer, detailing fabrication and assembly of door hardware, as well as installation procedures and diagrams. Coordinate final door hardware schedule with doors, frames, and related work to ensure proper size, thickness, hand, function, and finish of door hardware.
 - a. Submittal Sequence: Submit door hardware schedule concurrent with submissions of Product Data, Samples, and Shop Drawings. Coordinate submission of door hardware schedule with scheduling requirements of other work to facilitate the fabrication of other work that is critical in Project construction schedule.
 - b. Format: Comply with scheduling sequence and vertical format in the Door Hardware Institute's (DHI) "Sequence and Format

DIVISION 8 – OPENINGS

**Section
Number**

Title

for the Hardware Schedule." Double space entries, and number and date each page.

- c. Format: Use same scheduling sequence and format and use same door numbers as in the Contract Documents.
- d. Content: Include the following information:
 - 1) Identification number, location, hand, fire rating, size, and material of each door and frame.
 - 2) Locations of each door hardware set, cross-referenced to Drawings on floor plans and to door and frame schedule.
 - 3) Complete designations, including name and manufacturer, type, style, function, size, quantity, function, and finish of each door hardware product.
 - 4) Description of electrified door hardware sequences of operation and interfaces with other building control systems.
 - 5) Fastenings and other pertinent information.
 - 6) Explanation of abbreviations, symbols, and codes contained in schedule.
 - 7) Mounting locations for door hardware.
 - 8) List of related door devices specified in other Sections for each door and frame.

- 2. Keying Schedule: Prepared by Owner's Building Access Services department and incorporated into the finished hardware submittal and coordinated with the Contract Documents.

1.3 INFORMATIONAL SUBMITTALS

A. Qualification Data: For Installer.

B. Product Certificates: For electrified door hardware, from the manufacturer.

- 1. Certify that door hardware approved for use on types and sizes of labeled fire-rated doors complies with listed fire-rated door assemblies.

C. Product Test Reports: For compliance with accessibility requirements, based on evaluation of comprehensive tests performed by manufacturer and witnessed by a qualified testing agency, for door hardware on doors located in accessible routes.

1.4 CLOSEOUT SUBMITTALS

A. Maintenance Data: For each type of door hardware to include in maintenance manuals. Include final hardware and keying schedule.

DIVISION 8 – OPENINGS

Section Number	Title
1.5	<p>QUALITY ASSURANCE</p> <p>A. Installer Qualifications: Supplier of products and an employer of workers trained and approved by product manufacturers and an architectural hardware consultant who is available during the course of the Work to consult with Contractor, Design Professional, and Owner about door hardware and keying.</p> <ol style="list-style-type: none">1. Warehousing Facilities: In Project's vicinity.2. Scheduling Responsibility: Preparation of door hardware and keying schedules.3. Engineering Responsibility: Preparation of data for electrified door hardware, including Shop Drawings, based on testing and engineering analysis of manufacturer's standard units in assemblies similar to those indicated for this Project. <p>B. Architectural hardware consultant qualifications: A person who is experienced in providing consulting services for door hardware installations that are comparable in material, design, and extent to that indicated for this project and who is currently certified by Door Hardware Institute (DHI) as follows:</p> <ol style="list-style-type: none">1. For door hardware, an Architectural Hardware Consultant (AHC). <p>C. Source Limitations: Obtain each type of door hardware from a single manufacturer.</p> <ol style="list-style-type: none">1. Provide electrified door hardware from same manufacturer as mechanical door hardware, unless otherwise indicated. Manufacturers that perform electrical modifications and that are listed by a testing and inspecting agency acceptable to authorities having jurisdiction and approved by Owner are acceptable. <p>D. Fire-Rated Door Assemblies: Where fire-rated door assemblies are indicated, provide door hardware rated for use in assemblies complying with NFPA 80 that are listed and labeled by a qualified testing agency, for fire-protection ratings indicated, based on testing at positive pressure according to NFPA 252 or UL 10C, unless otherwise indicated.</p> <p>E. Smoke- and Draft-Control Door Assemblies: Where smoke- and draft-control door assemblies are required, provide door hardware that meet requirements of assemblies tested according to UL 1784 and installed in compliance with NFPA 105.</p> <ol style="list-style-type: none">1. Air Leakage Rate: Maximum air leakage of 0.3 cfm/sq. ft. at the tested pressure differential of 0.3-inch wg of water. <p>F. Electrified Door Hardware: Listed and labeled as defined in NFPA 70,</p>

DIVISION 8 – OPENINGS

Section
Number

Title

Article 100, by a testing agency acceptable to authorities having jurisdiction.

- G. Means of Egress Doors: Latches do not require more than 15 lbf to release the latch. Locks do not require use of a key, tool, or special knowledge for operation.
- H. Accessibility Requirements: For door hardware on doors in an accessible route, comply with the U.S. Architectural & Transportation Barriers Compliance Board's ADA-ABA Accessibility Guidelines.
 - 1. Provide operating devices that do not require tight grasping, pinching, or twisting of the wrist and that operate with a force of not more than 5 lbf.
 - 2. Comply with the following maximum opening-force requirements:
 - a. Interior, Non-Fire-Rated Hinged Doors: 5 lbf applied perpendicular to door.
 - b. Fire Doors: Minimum opening force allowable by authorities having jurisdiction.
 - 3. Bevel raised thresholds with a slope of not more than 1:12. Provide thresholds not more than 1/2 inch high per ANSI 117.1.
 - 4. Adjust door closer sweep periods so that, from an open position of 70 degrees, the door will take at least 3 seconds to move to a point 3 inches from the latch, measured to the leading edge of the door.
- I. Keying Conference: Conduct conference at Project site to comply with requirements in Division 1. In addition to Owner, Contractor, and Design Professional, conference participants shall also include installer's Architectural Hardware Consultant and Owner's security consultant. Incorporate keying conference decisions into final keying schedule after reviewing door hardware keying system including, but not limited to, the following:
 - 1. Function of building, flow of traffic, purpose of each area, degree of security required, and plans for future expansion.
 - 2. Preliminary key system schematic diagram.
 - 3. Requirements for key control system.
 - 4. Requirements for access control.
 - 5. Address for delivery of keys.
- J. Preinstallation Conference: Conduct conference at Project site.
 - 1. Review and finalize construction schedule and verify availability of materials, Installer's personnel, equipment, and facilities needed to make progress and avoid delays.
 - 2. Inspect and discuss preparatory work performed by other trades.
 - 3. Inspect and discuss electrical roughing-in for electrified door

DIVISION 8 – OPENINGS

Section Number	Title
	hardware.
	4. Review sequence of operation for each type of electrified door hardware.
	5. Review required testing, inspecting, and certifying procedures.
1.6	DELIVERY, STORAGE, AND HANDLING
	A. Inventory door hardware on receipt and provide secure lock-up for door hardware delivered to Project site.
	B. Tag each item or package separately with identification coordinated with the final door hardware schedule, and include installation instructions, templates, and necessary fasteners with each item or package.
	C. Deliver keys and permanent cores to Owner in-person or by registered mail or overnight package service to certify delivery. Owner is not responsible for packages lost in the mail, and Contractor shall resend at Contractor's expense.
1.7	COORDINATION
	A. Coordinate layout and installation of floor-recessed door hardware with floor construction. Cast anchoring inserts into concrete.
	B. Installation Templates: Distribute for doors, frames, and other work specified to be factory prepared. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing door hardware to comply with indicated requirements.
	C. Security: Coordinate installation of door hardware, keying, access control, automatic door operators and keyed cabinet hardware with Owner's security consultant.
	D. Electrical System Roughing-In: Coordinate layout and installation of electrified door hardware with connections to power supplies and building safety and security systems.
	E. Existing Openings: Where hardware components are scheduled for application to existing construction or where modifications to existing door hardware are required, field verify existing conditions and coordinate installation of door hardware to suit opening conditions and to provide proper door operation.
1.8	WARRANTY
	A. Special Warranty: Manufacturer's standard form in which

DIVISION 8 – OPENINGS

Section
Number

Title

manufacturer agrees to repair or replace components of door hardware that fail in materials or workmanship within specified warranty period.

1. Failures include, but are not limited to, the following:
 - a. Structural failures including excessive deflection, cracking, or breakage.
 - b. Faulty operation of doors and door hardware.
 - c. Deterioration of metals, metal finishes, and other materials beyond normal weathering and use.
2. Warranty Period: Three years from date of Substantial Completion, unless otherwise indicated.
 - a. Locks: Ten (10) years from date of Substantial Completion.
 - b. Electrified Locks: Two (2) years from date of Substantial Completion.
 - c. Exit Devices: Five (5) years from date of Substantial Completion.
 - d. Manual Closers: Thirty (30) years from date of Substantial Completion.
 - e. Strikes: Two (2) years from date of Substantial Completion.

PART 2 – PRODUCTS

2.1 SCHEDULED DOOR HARDWARE

- A. Provide door hardware for each door as scheduled in door hardware schedule to comply with requirements in this Section.
 1. Door Hardware Sets: Provide quantity, item, size, finish or color indicated, and products equivalent in function and comparable in quality to named products.
 2. Sequence of Operation: Provide electrified door hardware function, sequence of operation, and interface with other building control systems indicated.
- B. Designations: Requirements for design, grade, function, finish, size, and other distinctive qualities of each type of door hardware are indicated in door hardware schedule. Products are identified by using door hardware designations, as follows:
 1. Named Manufacturers' Products: Manufacturer and product designation are listed for each door hardware type required for the purpose of establishing minimum requirements. Manufacturers' names are abbreviated in door hardware schedule.
 2. References to Building Hardware Manufacturers Association (BHMA) Designations: Provide products complying with these

DIVISION 8 – OPENINGS

Section Number	Title
	designations and requirements for description, quality, and function.
2.2	HINGES A. Hinges: Follow BHMA A156.1. Provide template-produced hinges for hinges installed on hollow-metal doors and hollow-metal frames. 1. Butt Hinges a. Heavy weight ball bearing hinges or standard weight hinges (depending on installation location).
2.3	CONTINUOUS HINGES Continuous Hinges are not preferred by Owner due to heightened maintenance requirements.
2.4	MECHANICAL LOCKS AND LATCHES A. Cylindrical Locksets: Cylindrical locksets are the preferred standard. BHMA A156.13; Operational Grade 1; stamped steel case with steel or brass parts; a. Dormakaba 9K with 15D lever and small format interchangeable core. b. Assa Abloy Sargent 72-11 line with small format interchangeable core. c. Or approved equal with small format interchangeable core B. Mortise Locksets 1. Mortise locksets are not preferred due to heightened maintenance issues. C. Deadbolt locks: BHMA A156.12; Operational Grade 1; constructed of solid stainless steel deadbolt. Manufacturer to be approved as part of submittals process. D. Cylinders: to match existing or Owner-provided lockset.
2.5	ELECTROMECHANICAL LOCKS A. Electromechanical Locks: BHMA A156.25; Grade 1; motor or solenoid driven; mortise deadlocking latchbolt; with strike that suits frame. 1. Manufacturer to be approved on a project-by-project basis in discussion with Owner and Design Professional. a. Request-to-Exit built into the inside lever. b. Type to be determined for each project by Owner.
2.6	SELF-CONTAINED ELECTRONIC LOCKS A. Self-Contained Electronic Locks: BHMA A156.25, mortise; with

DIVISION 8 – OPENINGS

Section Number	Title
	<p>internal, battery-powered, self-contained electronic locks; consisting of complete lockset, motor-driven lock mechanism, and actuating device; enclosed in zinc-dichromate-plated, wrought-steel case, and strike that suits frame. Provide key override, low-battery detection and warning, LED status indicators, and ability to program at the lock.</p> <ol style="list-style-type: none">1. Manufacturer to be approved on a project-by-project basis in discussion with Owner and Design Professional.
2.7	<p>AUTOMATIC AND SELF-LATCHING FLUSH BOLTS</p> <ol style="list-style-type: none">A. Automatic and Self-Latching Flush Bolts: BHMA A156.16; minimum 3/4-inch throw; designed for mortising into door edge. Manufacturer to be approved on a project-by-project basis in discussion with Owner and Design Professional.
2.8	<p>EXIT DEVICES AND AUXILIARY ITEMS</p> <ol style="list-style-type: none">A. Exit Devices and Auxiliary Items: BHMA A156.3. Dormakaba, Assa Abloy, or approved equal.<ol style="list-style-type: none">a. Use rim type device with cylinder dogging. Precision Apex 2000-CD series or Sargent 16-80 series. or approved equal.b. Fire rated openings shall have devices related accordingly.c. Non-electronic exterior doors requiring panic hardware must have cylinder dogging feature (CD).d. Paired opening shall use 2 rim type devices with steel, keyed removable mullions provided by the same manufacturer as the exit devices.e. When electrified exit devices are used, they shall be by Precision. They shall have low voltage motorized latch retraction with Request-To-Exit switches. Power Supplies shall be of the same exit device manufacturer.f. Electrified Exit device trims shall not be used unless driven by code requirements.
2.9	<p>PERMANENT CORES (Small Format Interchangeable Cores)</p> <ol style="list-style-type: none">A. Permanent cores: Tumbler type, constructed from brass or bronze, stainless steel, or nickel silver.<ol style="list-style-type: none">1. Best Locks, a Dormakaba Company<ol style="list-style-type: none">a. Small Format 7 pin removable coreb. Provide construction cores that are replaceable by permanent cores.
2.10	<p>KEYING</p> <ol style="list-style-type: none">A. Keying System:<ol style="list-style-type: none">1. Best Locks, a Dormakaba Company<ol style="list-style-type: none">a. All cores to be Best 7 pin interchangeable cores 1CP7 provided

DIVISION 8 – OPENINGS

Section Number	Title
	and installed by NAU. Provide all cylinders and locksets with temporary brass 7-pin interchangeable cores during construction.
	B. Keys: Provided by Owner
2.11	KEY CONTROL SYSTEM
	A. Key Control Cabinet: VERIFY WITH OWNER IF REQUIRED FOR EACH PROJECT.
	B. Key Lock Boxes: VERIFY WITH OWNER IF REQUIRED FOR EACH PROJECT.
2.12	SURFACE CLOSERS
	A. Surface Closers: BHMA A156.4; rack-and-pinion hydraulic type with adjustable sweep and latch speeds controlled by key-operated valves and forged-steel main arm. Comply with manufacturer's written recommendations for size of door closers depending on size of door, exposure to weather, and anticipated frequency of use. Provide factory-sized closers, adjustable to meet field conditions and requirements for opening force.
	1. Norton Closers
	a. 7500 (PR) (TBGN) surface mounted series with Extra Heavy Duty arms.
	b. Closer with stop arm (CPS) shall be used when doors swing only 90 degrees.
	c. Hold Open arms shall NOT be used unless designated by the Owner.
	d. Gate Closers shall conform to these same standards.
	2. Allegion LCN 4040XP-EDA-TBWMS-ALUM closers must be installed by through-bolting the closer (with sexnuts) to the door with 1/4-20 hardware. The closer shoe must be attached to the frame by all five mounting points. In the case of aluminum frames, the shoe must be attached with 1/4-20 nutserts (aka rivetnuts) installed in the frame and using LCN 4040-61 Blade Stop Spacers. If necessary due to inadequate jamb reveal, the fifth attachment point will be accomplished by using LCN 4040-30 Cush Shoe Supports.
	3. Or approved equal.
2.13	MECHANICAL STOPS AND HOLDERS
	A. Wall- and Floor-Mounted Stops: BHMA A156.16; aluminum base metal.
	1. IVES Hardware, Trimco Manufacturing and Rockwood
	a. Heavy Duty Floor type stop, Ives FS18S or Trimco 1209 or

DIVISION 8 – OPENINGS

Section Number	Title
	Rockwood 466-RKW in black.
	b. Convex or concave wall stops depending on locking hardware. Ives WS401 series or Trimco 1270 series or Rockwood 400/401 with appropriate securing packs for the application.
	c. Or approved equal.
2.14	ELECTRONIC STOPS AND HOLDERS
	A. Wall Mount: BHMA A156
	1. Dormakaba, Rixson, or approved equal.
	a. All metal housing, standard profile with recessed wall mount.
	b. They shall be tri-voltage with pivoting armatures.
2.15	OVERHEAD STOPS AND HOLDERS
	A. Overhead Stops and Holders: BHMA A156.8.
	1. Glynn Johnson, Rixson, or approved equal
	a. Glynn Johnson 900 Series surface mounted.
	b. Rixson 9 Series surface mounted.
2.16	METAL PROTECTIVE TRIM UNITS
	A. Metal Protective Trim Units: BHMA A156.6; fabricated from 0.050-inch-thick stainless steel; with manufacturer's standard machine or self-tapping screw fasteners.
	1. IVES Hardware or Trimco Manufacturing or Rockwood or approved equal
	a. Kick plates and armor plates shall be .050 gage stainless steel, 12 inches high, beveled 4 sides with countersunk screws.
	b. Latch Guards on all exterior doors
2.17	DOOR GASKETING
	A. Door Gasketing: BHMA A156.22; air leakage not to exceed 0.50 cfm per foot of crack length for gasketing other than for smoke control, as tested according to ASTM E 283; with resilient or flexible seal strips that are easily replaceable and readily available from stocks maintained by manufacturer.
	1. Zero International, Reese, or National Guard or Pemko products or approved equal.
	a. Brush Type seals are the preference
2.18	THRESHOLDS
	A. Thresholds: BHMA A156.21; fabricated to full width of opening indicated.
	1. Zero International, Reese, or National Guard or Pemko products or approved equal.

DIVISION 8 – OPENINGS

Section Number	Title
2.19	FINISHES
	A. Provide finishes complying with BHMA A156.18 as indicated in door hardware schedule.
	B. Protect mechanical finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
	C. Appearance of Finished Work: Variations in appearance of abutting or adjacent pieces are acceptable if they are within one-half of the range of approved Samples. Noticeable variations in the same piece are not acceptable. Variations in appearance of other components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.

PART 3 - EXECUTION

3.1	EXAMINATION
	A. Examine doors and frames, with Installer present, for compliance with requirements for installation tolerances, labeled fire-rated door assembly construction, wall and floor construction, and other conditions affecting performance.
	B. Examine roughing-in for electrical power systems to verify actual locations of wiring connections before electrified door hardware installation.
	C. Proceed with installation only after unsatisfactory conditions have been corrected.
3.2	PREPARATION
	A. Steel Doors and Frames: For surface applied door hardware, drill and tap doors and frames according to ANSI/SDI A250.6.
	B. Wood Doors: Comply with DHI WDHS.5 "Recommended Hardware Reinforcement Locations for Mineral Core Wood Flush Doors."
3.3	INSTALLATION
	A. Mounting Heights: Mount door hardware units at heights indicated on Drawings unless otherwise indicated or required to comply with governing regulations.
	1. Standard Steel Doors and Frames: ANSI/SDI A250.8.
	2. Custom Steel Doors and Frames: HMMA 831.
	3. Wood Doors: DHI WDHS.3, "Recommended Locations for

DIVISION 8 – OPENINGS

Section
Number

Title

Architectural Hardware for Wood Flush Doors."

- B. Install each door hardware item to comply with manufacturer's written instructions. Where cutting and fitting are required to install door hardware onto or into surfaces that are later to be painted or finished in another way, coordinate removal, storage, and reinstallation of surface protective trim units with finishing. Do not install surface-mounted items until finishes have been completed on substrates involved.
 - 1. Set units level, plumb, and true to line and location. Adjust and reinforce attachment substrates as necessary for proper installation and operation.
 - 2. Drill and countersink units that are not factory prepared for anchorage fasteners. Space fasteners and anchors according to industry standards.
- C. Hinges: Install types and in quantities indicated in door hardware schedule but not fewer than the number recommended by manufacturer for application indicated or one hinge for every 30 inches of door height, whichever is more stringent, unless other equivalent means of support for door, such as spring hinges or pivots, are provided.
- D. Intermediate Offset Pivots: Where offset pivots are indicated, provide intermediate offset pivots in quantities indicated in door hardware schedule but not fewer than one intermediate offset pivot per door and one additional intermediate offset pivot for every 30 inches of door height greater than 90 inches.
- E. Lock Cylinders: Install construction cores to secure building and areas during construction period.
 - 1. Replace construction cores with permanent cores as directed by Owner.
 - 2. Furnish permanent cores to Owner for installation.
- F. Boxed Power Supplies: Locate power supplies as indicated or, if not indicated, above accessible ceilings. Verify location with Design Professional.
 - 1. Configuration: Provide least number of power supplies required to adequately serve doors with electrified door hardware.
- G. Thresholds: Set thresholds for exterior doors and other doors indicated in full bed of sealant complying with requirements specified in Section 07 92 00 "Joint Sealants and Caulking".

DIVISION 8 – OPENINGS

Section
Number

Title

- H. Stops: Provide floor stops for doors unless wall or other type stops are indicated in door hardware schedule. Do not mount floor stops where they will impede traffic.
- I. Perimeter Gasketing: Apply to head and jamb, forming seal between door and frame.
- J. Meeting Stile Gasketing: Fasten to meeting stiles, forming seal when doors are closed.
- K. Door Bottoms: Apply to bottom of door, forming seal with threshold when door is closed.

3.4 ADJUSTING

- A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.
 - 1. Spring Hinges: Adjust to achieve positive latching when door is allowed to close freely from an open position of 30 degrees.
 - 2. Electric Strikes: Adjust horizontal and vertical alignment of keeper to properly engage lock bolt.
 - 3. Door Closers: Adjust sweep period to comply with accessibility requirements and requirements of authorities having jurisdiction.
- B. Occupancy Adjustment: Approximately three months after date of Substantial Completion, installer's Architectural Hardware Consultant shall examine and readjust each item of door hardware, including adjusting operating forces, as necessary to ensure function of doors, door hardware, and electrified door hardware.

3.5 CLEANING AND PROTECTION

- A. Clean adjacent surfaces soiled by door hardware installation.
- B. Clean operating items as necessary to restore proper function and finish.
- C. Provide final protection and maintain conditions that ensure that door hardware is without damage or deterioration at time of Substantial Completion.

DIVISION 8 – OPENINGS

**Section
Number
08 80 00
08 81 00**

Title

GLAZING

Glass Glazing

Part 1 – General

Dual pane 1" insulated glass at a minimum shall be on all exterior windows.

Side lights and/or door lights to be tempered float glass.

All glass within contact by pedestrian traffic to be tempered.

Individual windows or window assemblies shall easily accommodate washing of the exterior surface.

Exterior ledges of window openings shall allow proper drainage away from the window assembly, 1/2" per foot minimum.

All window assemblies shall be fully weatherstripped and gasketed.

All glass types shall be a local stock item to eliminated replacement delays.

Part 2 – Products

N/A

Part 3 – Execution

N/A

*** * * END OF SECTION * * ***