

Facility Services: Planning, Design & Construction
PO Box 5637
Flagstaff, AZ 86011

928.523.4468
<https://in.nau.edu/facility-services/pdc/>

**New Nursing Facility
NAU Project #09.340.261
January 9, 2026**

CLARIFICATION #1

PART 1 – GENERAL

- A. Date of Issue: January 9, 2026
- B. The following Clarification is for informational purposes only and is in response to a question received on the Attachment C: Submittal Inquiry Form for the Request for Qualifications for Design Professional Services, Project #09.340.261 - New Nursing Facility.

PART 2 – CLARIFICATIONS

1. **Question:** What campus utilities affected by the demolition must be maintained for serving other university facilities during construction?
Response: *Steam is the only utility that needs to be maintained through the campus utility tunnel system that runs adjacent to north edge of the proposed construction site.*

END OF CLARIFICATION #1