

Solar Power Variations in the Regulation and Sub-Regulation Time Frames

Thomas L. Acker, David M. Willy
Institute for Sustainable Energy Solutions

Ronald. K. Flood
Arizona Public Service Company

ASES Solar 2014, San Francisco CA
July 8, 2014

NORTHERN
ARIZONA
UNIVERSITY



FLAGSTAFF
FOUNDED 1899



Outline

- Arizona Public Service Solar Variability Study
- Integration and interconnection of renewables: “regulation”
- Defining “Regulation” and “Sub-Regulation”
- Results



Solar Power Integration and Interconnection

- For our purposes, when connecting solar power to the grid, consider:
 - *Integration* – the effects of variable and uncertain renewable energy on net load balance, power quality, and reliability that can be handled during system operation via provision of “ancillary services” such as regulation.
 - *Interconnection* – the hardware/software build into the distribution system to ensure the power quality on the distribution or transmission line is acceptable



“Regulation”

- Short term variability
- Units on AGC
- 1-min load data
- Load trend based on a 20-min rolling average
- Regulation can be characterized using the standard deviation of the 1-min (load – trend) data

Example:

$$\sigma_{\text{Load}} = 10 \text{ MW}$$

$$\text{Reg} = 5 \times \sigma_{\text{Load}} = 50 \text{ MW}$$



Regulation Impact of RE

Assume *1-min* load and renewable energy (solar or wind)
fluctuations are uncorrelated

$$\sigma_{\text{Load}} = 10 \text{ MW}$$

$$\text{Reg}_{\text{Load}} = 5 \times \sigma_{\text{Load}} = 50 \text{ MW}$$

Add variable renewable energy:


$$\sigma_{\text{RE}} = 1 \text{ MW}$$

$$\sigma_{\text{Load+RE}} = \sqrt{(\sigma_{\text{Load}})^2 + (\sigma_{\text{RE}})^2} = 10.05 \text{ MW}$$

$$\Delta \text{Reg}_{\text{Load+RE}} = 5 \times (\sigma_{\text{Load+RE}} - \sigma_{\text{Load}}) = 0.05 \text{ MW}$$


So, it is useful to know the std. dev. of 1-min fluctuations

Regulation and Sub-Regulation




Regulation vs. Sub-Regulation

Sub-regulation: 03/07/11




Regulation: 03/07/11




		σ (kW)	Min (kW)	Max (kW)
February, March, and April	Reg	84.0	-1352	1218
	Subreg	34.7	-1277	1173

Ramp in Sub-Reg Time Series


Ramp rates: 03/07/11



Ramp Events



At Output of PV Plant



Conclusions

- “Sub-Regulation” defined to identify rapid fluctuations from a PV power plant that must be handled during interconnection
- Large, rapid fluctuation in the PV plant output were identified
- Rapid power fluctuations were found to be correlated with some changes in feeder voltage, but in no case did the voltage exceed the regulation band and have a deleterious effect on the distribution line



Thank you!

*Thomas L. Acker, Ph.D.
David M. Willy
Institute for Sustainable Energy
Solutions
Northern Arizona University
15600 S McConnell Dr., Bldg. 69
Flagstaff, AZ 86011
Tom.Acker@nau.edu
David.Willy@nau.edu*

*Ronald K. Flood
Senior Consulting Engineer
Arizona Public Service Company
Technology Assessment and
Interconnection
400 N. 5th Street, MS 9659
Phoenix, Az. 85004
Ronald.Flood@aps.com*

**NORTHERN
ARIZONA
UNIVERSITY**



**FLAGSTAFF
FOUNDED 1899**



Appendix

NORTHERN
ARIZONA
UNIVERSITY



FLAGSTAFF
FOUNDED 1899


References


- (1) Greentech Media, Inc. and Solar Energy Industries Association. “U.S. Solar Market Insight Report, Q1 2014, Executive Summary.” Web. < <http://www.seia.org/research-resources/us-solar-market-insight> >
- (2) Flood, R.K., Acker, T.L., Willy, D., Lerner J., and A. Vandervoort, "Prescott airport solar facility solar variability study." 2011. Web. 1 May 2014.
< <https://www.aps.com/library/renewables/PrescottVariability.pdf> >
- (3) Acker, T.L, Zavadil, R., Potter, C., and R. Flood. “Final Report: Arizona Public Service Wind Integration Cost Impact Study.” *Wind Engineering*, vol.32, no.4, 2008, pgs. 339-354.
- (4) Holttinen, H., Milligan, M., Kirby, B., Acker, T., Neimane, V., and T. Molinski. “Using Standard Deviation as a Measure of Increased Operational Reserve Requirement for Wind Power” *Wind Engineering*, vol.32, no.4, 2008, pgs. 355-378.

Table of Results


		σ (kW)	Min (kW)	Max (kW)	95.5% (kW)	99.0% (kW)	99.7% (kW)	99.9% (kW)
3/7/2011: relatively cloudy	Reg	219	-1066	1218	606	853	1027	1096
	Subreg	113	-923	1134	287	540	689	794
3/8/2011: relatively clear	Reg	8.6	-89.3	79.7	15.3	39.7	66.7	79.2
	Subreg	3.6	-67.2	34.9	8.1	15.4	21.7	27.3
February	Reg	67.7	-1195	1090	120	352	557	771
	Subreg	29.0	-1118	832	28.8	128	254	379
March	Reg	90.5	-1275	1218	180	470	731	917
	Subreg	35.4	-1030	1134	46.5	160	295	452
April	Reg	90.5	-1352	1125	162	495	752	949
	Subreg	38.5	-1277	1173	40.4	172	332	497
February, March, and April	Reg	84.0	-1352	1218	155	438	698	901
	Subreg	34.7	-1277	1173	39.0	154	296	445

1-second Ramp Events





Ramp Events



Sky Imagery

